


**SYMBOLS LEGEND**

SYMBOL	DESCRIPTION
Ⓜ	FIRE ALARM CONTROL PANEL
Ⓜ-1	A/V BOOSTER POWER SUPPLY # / NUMBER
Ⓜ-2	FIRE ALARM ANNUNCIATOR PANEL
Ⓜ-3	AREA RESCUE CONTROL PANEL
Ⓜ-4	COMMUNICATION SYSTEM CALL BOX
Ⓜ-5	MANUAL PULL STATION
Ⓜ-6	PHOTOELECTRIC SMOKE DETECTOR
Ⓜ-7	COMBINATION PHOTOELECTRIC SMOKE & CO DETECTOR
Ⓜ-8	120V PHOTOELECTRIC SMOKE ALARM DETECTOR
Ⓜ-9	HEAT DETECTOR
Ⓜ-10	PHOTOELECTRIC DUCT SMOKE DETECTOR (F.S.O.)
Ⓜ-11	STROBE UNIT # / CANDELA RATING - WALL MOUNTED
Ⓜ-12	HORN/STROBE UNIT # / CANDELA RATING - WALL MOUNTED
Ⓜ-13	LOW FREQUENCY HORN UNIT - WALL MOUNTED
Ⓜ-14	SPRINKLER FLOW SWITCH
Ⓜ-15	SPRINKLER VALVE TAMPER SWITCH
Ⓜ-16	24V DOOR HOLDER
Ⓜ-17	DOOR RELEASE RELAY
Ⓜ-18	ELEVATOR RECALL RELAY - PRIMARY & ALTERNATE
Ⓜ-19	ELEVATOR POWER SHUNT-TRIP RELAY
Ⓜ-20	ELEVATOR POWER SHUNT-TRIP STATUS MONITOR
Ⓜ-21	ELEVATOR CAR LIGHT RELAY
Ⓜ-22	120V SMOKE ALARM DETECTOR STATUS MONITOR
Ⓜ-23	CONTROL RELAY MODULE
Ⓜ-24	MONITOR MODULE (SINGLE ZONE)
Ⓜ-25	DUCT DETECTOR MONITOR MODULE
Ⓜ-26	DENOTES EXISTING DEVICE TO REMAIN UNCHANGED
Ⓜ-27	DENOTES AREA NOT IN CONTRACT
Ⓜ-28	STROBE CIRCUIT (BOOSTER # / CIRCUIT #) TYPICAL
Ⓜ-29	CIRCUIT HOVER/IN
Ⓜ-30	END OF LINE RESISTOR

**GRAPHIC SCALE:**



ARK JOB # 24K282

**ARK SYSTEMS**  
 1000 WASHINGTON BLVD  
 COLUMBIA, MARYLAND 21046  
 (410) 271-1100

Electrical Contractor:  
**CROWN ELECTRIC**

Rev. #	Description	Date	Approved

**LOREN ELKRIDGE - ASSISTED LIVING ADDITION**  
 7615 WASHINGTON BLVD, ELKRIDGE, MD 21075

**FIRE ALARM DEVICE LAYOUT**  
 GROUND FLOOR

ISSUED BY: AMS DATE: 11-15-19 SCALE: 1/8" = 1'-0" FA-1  
 CHECKED BY: CHG