



SYMBOLS LEGEND

SYMBOL	DESCRIPTION
	FIRE ALARM CONTROL PANEL
	A/V BOOSTER POWER SUPPLY # / NUMBER
	FIRE ALARM ANNUNCIATOR PANEL
	AREA RESCUE CONTROL PANEL
	COMMUNICATION SYSTEM CALL BOX
	MANUAL PULL STATION
	PHOTOELECTRIC SMOKE DETECTOR
	COMBINATION PHOTOELECTRIC SMOKE & CO DETECTOR
	120V PHOTOELECTRIC SMOKE ALARM DETECTOR
	HEAT DETECTOR
	PHOTOELECTRIC DUCT SMOKE DETECTOR (F.S.O.)
	STROBE UNIT # / CANDELA RATING - WALL MOUNTED
	HORN/STROBE UNIT # / CANDELA RATING - WALL MOUNTED
	LOW FREQUENCY HORN UNIT - WALL MOUNTED
	SPRINKLER FLOW SWITCH
	SPRINKLER VALVE TAMPER SWITCH
	24V DOOR HOLDER
	DOOR RELEASE RELAY
	ELEVATOR RECALL RELAY - PRIMARY & ALTERNATE
	ELEVATOR POWER SHUNT-TRIP RELAY
	ELEVATOR POWER SHUNT-TRIP STATUS MONITOR
	ELEVATOR CAB LIGHT RELAY
	120V SMOKE ALARM DETECTOR STATUS MONITOR
	CONTROL RELAY MODULE
	DUCT DETECTOR MONITOR MODULE
	MONITOR MODULE (SINGLE ZONE)
	EXISTING DEVICE TO REMAIN UNCHANGED
	STROKE CIRCUIT (BOOSTER #1 / CIRCUIT #1) TYPICAL
	CIRCUIT HORN/STR
	END OF LINE RESISTOR

GRAPHIC SCALE:
 1/8" = 1'-0"
 0 4 8 16 24

ARK JOB # 21K282

ARK
 fire alarm systems
 6176 BERRY BRANCH ROAD
 GAITHERSBURG, MARYLAND 20878
 (301) 841-2299

Electrical Contractor:
CROWN ELECTRIC

Rev. #	Description	Date	Approved

LORIEN EKBRIDGE - ASSISTED LIVING ADDITION
7615 WASHINGTON BLVD. EKBRIDGE, MD 21075

SECOND FLOOR
FIRE ALARM DEVICE LAYOUT

DRAWN BY: AMS DATE: 11-15-19
 CHECKED BY: CHG SCALE: 1/8" = 1'-0" **FA-3**