



SYMBOLS LEGEND

SYMBOL	DESCRIPTION
	FIRE ALARM CONTROL PANEL
	A/V BOOSTER POWER SUPPLY w/ NUMBER
	FIRE ALARM ANNUCIATOR PANEL
	AREA RESCUE CONTROL PANEL
	COMMUNICATION SYSTEM CALL BOX
	MANUAL PULL STATION
	PHOTOELECTRIC SMOKE DETECTOR
	COMBINATION PHOTOELECTRIC SMOKE & CO DETECTOR
	120V PHOTOELECTRIC SMOKE ALARM DETECTOR
	HEAT DETECTOR
	PHOTOELECTRIC DUCT SMOKE DETECTOR (S.A.O.)
	STROBE UNIT w/ CANDELA RATING - WALL MOUNTED
	HORN/STROBE UNIT w/ CANDELA RATING - WALL MOUNTED
	LOW FREQUENCY HORN UNIT - WALL MOUNTED
	SPRINKLER FLOW SWITCH
	SPRINKLER VALVE TAMPER SWITCH
	24V DOOR HOLDER
	DOOR RELEASE RELAY
	ELEVATOR RECALL RELAY - PRIMARY & ALTERNATE
	ELEVATOR POWER SHUNT-TTRIP STATUS MONITOR
	ELEVATOR CAB LIGHT RELAY
	120V SMOKE ALARM DETECTOR STATUS MONITOR
	CONTROL RELAY MODULE
	MONITOR MODULE (SINGLE ZONE)
	DUCT DETECTOR MONITOR MODULE
	DUCTS EXISTING DEVICE TO REMAIN UNCHANGED
	DUCTS AREA NOT IN CONTRACT
	STROBE CIRCUIT (BOOSTER #) / CIRCUIT #1 TYPICAL
	CIRCUIT HORN/IBN
	END OF LINE RESISTOR

GRAPHIC SCALE:
1/8" = 1'-0"
0 4 8 16 24

ARK JOB # 2JK282
ARK
systems
1570 AREA MANAGER ROAD
GAITHERSBURG, MARYLAND 20878
WASHINGTON, DISTRICT OF COLUMBIA 20004
(301) 941-8298

Rev. #	Description	Date	Approved
Electrical Contractor: CROWN ELECTRIC			
LORLEN ELKBRIDGE - ASSISTED LIVING ADDITION 7615 WASHINGTON BLVD. ELKBRIDGE, MD 21075 THIRD FLOOR FIRE ALARM DEVICE LAYOUT FA-4			
Drawn By: AMS	DATE: 11-15-19		
Checked By: CHG	SCALE: 1/8" = 1'-0"		