

SPECIFICATION NOTES

DIVISION 1 - GENERAL REQUIREMENTS

011000 SUMMARY OF WORK

A. Unless otherwise noted, "The Owner" refers to the person, organization and/or business entering into an agreement with the Contractor to execute the Work indicated in the Contract Documents. The Contractor's responsibilities to each party are described in the specifications and documents below.

B. The "Work" includes the new construction of a stand alone building including: Concrete slab on grade, steel framing and steel stud infill exterior walls, steel bar joists, steel roof deck, membrane roof, aluminum storefront system, cultured stone, thin brick, and fiber cement exterior finishes, steel stud and gypsum board interior partitions, finishes, and HVAC, plumbing, and electrical systems.

C. Owner-supplied items include:

1. Exterior building signage
2. Data and telephone cabling and equipment
3. Security system and equipment
4. Audio visual equipment
5. Point of sale (POS) equipment

D. Permits and Inspections

1. The Contractor is responsible for obtaining all necessary utilities permits required to perform the Work.
2. The Contractor is responsible for inspections required for the jurisdiction in which the Work is performed. Verify with local regulatory agency exact number, type and schedule of inspections required for the Work prior to commencing with the Work.
3. The Contractor shall provide the Owner with documentation and scheduling necessary for Occupancy Permit.
4. The Building Permit will be obtained by an agent of the Owner.

E. Contract Documents

1. The AIA "General Conditions of the Contract for Construction" AIA Document A201, 1997 edition, published by the American Institute of Architects, hereinafter referred to as "General Conditions", is hereby made part of the Contract Documents, the same as if found herein.
2. The Contract Documents consist of the following:
  - a. Owner-Contractor Agreement ("The Contract")
  - b. General Conditions
  - c. Drawings as dated in agreement ("The Drawings")
  - d. Addenda
  - e. Modifications
3. The Contract Documents are instruments of service and shall remain the property of the Owner whether the project for which they are prepared is executed or not.

01025 MEASUREMENTS AND PAYMENT

- A. Prior to commencing with the work, the Contractor shall submit to the Owner the following information:
1. A Schedule of Values indicating the components of Work listed in sufficient detail to the satisfaction of the Owner to serve as a basis for computing values for Applications for Payments during construction.
  2. A construction schedule for the Work in bar chart form. This schedule will be used as the basis for evaluating progress of the Work and Applications for Payments.

B. Applications for Payment shall use AIA Document G702. Applications are to be notated and bear the signature of an authorized officer.

C. Only approved Change Orders are to be indicated on Applications for Payment.

012500 SUBSTITUTIONS

- A. The Contractor's bid shall be based on providing all specified items. Substitutions shall be considered only under the following circumstances:
1. The specified item is accompanied by the words "equal to". References to makes, brands, models, etc. is to establish type and quality desired.
  2. The item is shown to have a prohibitively long lead time.
  3. An item of equal appearance and equal or greater quality to the specified item can be provided at substantial savings to the Owner.
- B. Substitutions shall be considered by the Owner for acceptance under the following procedure.
1. The Contractor shall make all requests for substitutions within seven (7) days of the contract award.
  2. The Owner requires seven (7) days for review of the Contractor's request for substitution.
  3. The Contractor's request for substitution shall include information and samples as deemed necessary by the Owner of both the specified item and proposed substitution. Characteristics of both products shall be clearly identified for the Architect's evaluation.

013100 PROJECT OWNER'S COORDINATION

- A. Coordination with Owner - Supplied items:
1. Make necessary provisions for items to be furnished or installed by Owner as indicated on the drawings. Such provisions include, but are not limited to, plumbing & electrical requirements.
  2. Provide protection for Owner-supplied items until completion of the project.
  3. The Contractor is to include the installation cost of Owner-supplied items unless otherwise noted.
  4. Any ambiguity or need for clarification regarding scope of Work related to Owner-supplied items is to be reviewed with the Architect prior to commencing with the Work.
  5. Telephone and data work shall be coordinated by the Contractor with Owner's representative.
  6. Security system work shall be coordinated by the Contractor with the Owner's representative.

B. Prior to construction, the Contractor shall verify that no conflicts exist in locations of any mechanical, electrical, plumbing and sprinkler equipment (to include piping, duct work, structural members and conduit) and that required clearances for installation and maintenance of above equipment are provided. Elements in conflict shall be determined and reviewed with Architect for resolution prior to construction.

C. Contractor shall order and schedule delivery of materials in ample time to avoid delays in construction. If an item is found to be unavailable or have a long lead time, the Contractor shall notify Owner within seven (7) days of contract award.

01060 REGULATORY REQUIREMENTS

A. The Work shall comply with applicable codes, amendments, rules, regulations, ordinances, laws, orders, approvals, etc. that are required by the public authorities. In the event of conflict, the most stringent requirements shall govern. Requirements include, but are not necessarily limited to, the currently applicable editions or publications of the codes as listed on the Project Information sheet on the drawings.

B. Install building standard fire extinguishers and cabinets where required by applicable codes as directed by the Owner (Provide and install any additional code-required fire extinguishers and cabinets where directed by code officials and/or the Owner).

013300 SUBMITTALS

- A. Within seven (7) days of the contract award, the Contractor shall submit to the Owner a schedule of all submittals identifying estimated date of submission. Submittals shall include but are not limited to:
1. Finishes
  2. Doors, frames, and hardware
  3. Glass
  4. Metals
  5. Equipment
  6. Mechanical equipment, diffusers, grilles, devices, etc.
  7. Electrical equipment, light fixtures, controls, devices, etc.
  8. Plumbing equipment, fixtures, devices, etc.
- B. Preparation of submittals shall be as follows:
1. Submit one (1) reproducible copy and two (2) prints of each shop drawing.
  2. For catalog cuts, brochures, and other standard printed or published product data, submit number of copies needed by Contractor, plus two (2) copies to be retained by Owner.
  3. The Contractor shall submit a minimum of three (3) samples of finishes. The Owner shall retain two (2) samples for review and approval prior to ordering or proceeding with the Work. No construction shall proceed until submittals are approved.
- C. The Contractor shall provide manufacturer's specifications, installation instructions, shop drawings and samples for review and approval prior to ordering or proceeding with the Work. No construction shall proceed until submittals are approved.
- D. Contractor shall allow seven (7) working days for the Owner and Consultants to review submittals. All submittals not reviewed directly by the Owner, but rather Consultants to the Owner, shall be submitted simultaneously to both Owner and the Consultant and shall be noted as such. The Contractor shall not proceed with work until the Owner has approved the submittal. No extension of the contract time will be granted because of failure to provide submittals for the Owner's review or coordination in a timely fashion.
- E. The Owner reserves the right to reject any and all items installed without prior review and approval by the Owner.
- F. Refer to specified items for specific submittal requirements.

014000 QUALITY REQUIREMENTS

- A. Dimensions and Tolerances:
1. Do not scale drawings; dimensions govern. Verify dimensions with field conditions. If discrepancies are discovered between field conditions and drawings or between drawings, contact the Owner for resolution before proceeding.
  2. Horizontal dimensions indicated are to/ from finished face of construction, except as noted.
  3. Vertical dimensions are from top of floor slab, except where noted to be from above finished floor (AFF), as measured from the high point of the slab. Contractor to notify the Architect when deviation is greater than allowed in note 4 below.
  4. Floor Tolerance: The Contractor is to immediately verify slope and report and deviation over 1/4 inch in slope in 10 feet to the Architect prior to commencing Work. The Contractor shall be responsible for leveling all areas to achieve a slope deviation of less than 1/4 inch slope in 10 feet. The Contractor shall ensure an absolute level floor under all swinging and sliding doors.
  5. Dimensions are not adjustable without approval of the Architect unless noted (+/-).
  6. Dimensions indicated to be "clear" or "c/c" shall be maintained. Any discrepancies or variations in these dimensions shall be reviewed with the architects before beginning construction.
  7. Any dimension noted "Verify" or "VIF" must be reviewed with the Architect before beginning construction.
  8. The Contractor shall continuously check Architectural and structural clearances for accessibility of equipment and mechanical and electrical systems. No allowance of any kind will be made for the Contractor's failure to foresee means of installing equipment into position inside structures.

B. Observation of Work

1. The Owner or Owner's designated agent for design of this project, will exercise sole authority for determining conformance of materials, equipment and systems with the intent of the design. Review and acceptance of items proposed by Contractor for incorporation into the Work will be by the Owner. This function of the Owner will apply both to Contract as initially signed, and to the changes to Contract by modification during progress of Work.
2. If at any time before commencement of Work, or during progress thereof, the Contractor's methods, equipment or appliances are inefficient or inappropriate for securing quality of Work, or rate of progress intended by Contract Documents, the Owner may order the Contractor to improve their quality or increase their efficiency. This will not relieve the Contractor of his sureties from their obligations to secure quality of Work and rate of Progress specified in contract.

C. Reference to Standards

1. Materials and workmanship specified by reference to number symbol, to title of a specification such as commercial standards, federal specification, trade association standard, or other similar standard, shall comply with requirements in latest edition or revision thereof and with any amendment or supplement thereto in effect on date of origin of this project's Contract Documents. Such standard, except as modified herein, shall have full force and effect as though printed in Contract Documents.
2. The Contractor shall have "Common Practice" and "Common Usage" as construction criteria wherever details and Contract Documents or governing codes, ordinances, etc. require greater quantity than common practice or common usage would require.

D. In the event of conflict between the Drawings and the Specifications, the Specifications shall govern. Detail drawings take precedence over drawings of larger scope. Should the Contractor at any time discover an error in a drawing or specification, or a discrepancy or variation between drawings, or a discrepancy or variation between dimensions and measurements at site, or lack of dimensions or other information, the Contractor shall not proceed with the Work affected until clarification has been made.

E. The Contractor shall coordinate and review the layout and exact location of the items listed below in the field prior to construction. Any conflicts that arise shall be brought to the Architect's attention in writing for resolution prior to proceeding with construction:

1. Partitions
2. Doors
3. Core drill locations
4. Electrical/data outlets
5. Thermostats
6. Light Switches
7. Light fixtures
8. Changes in ceiling plane, and other ceiling features
9. VAV boxes, supplemental AC units and other mechanical, electrical, or plumbing items requiring ceiling access or affecting ceiling height
10. Kitchen equipment, exhaust hood, condensate drains, floor sinks, utility connections

F. The Contractor shall follow manufacturer's recommended specification and installation procedures. If these are contrary to the Contract Documents, the Contractor shall notify the Architect, in writing, immediately, to resolve discrepancies prior to proceeding.

G. Only new items of recent manufacturer's, of the highest quality, free from defects, will be permitted on the Work. Rejected items shall be removed immediately from the Work and replaced with items of the quality specified. Failure to remove rejected materials and equipment shall not relieve the Contractor from the responsibility for quality and character of items used nor from any other obligation imposed by the Contract.

H. The finished Work shall be firm, well anchored, in true alignment, plumb, level, with smooth, clean, uniform appearance without waves, distortions, holes, marks, cracks, stains, or discoloration. Joints shall be close fitting, neat and well scribed. The finish work shall have no exposed unsightly anchors or fasteners and shall not present hazardous, unsafe corners. Work shall have the provision for expansion, contraction, and shrinkage as necessary to prevent cracks, buckling and warping due to temperature and humidity conditions.

I. Attachments, connections, or fastenings of any nature are to be properly and permanently secured in conformance with best practice and the Contractor is responsible for improving them accordingly. The drawings show only special conditions to assist the Contractor. They do not illustrate every such detail.

J. No Work defective in construction or quality or deficient in any requirements of drawings and specifications will be acceptable in consequence of the Owner's or Architect's failure to discover or to point out defects or deficiencies during construction; nor will presence of inspectors in Work relieve the Contractor from responsibility for securing quality and progress of Work as required by the Contract. Defective Work revealed within required time guarantees, as specified in the Contract, shall be replaced by Work conforming with the intent of the contract. No payment whether partial or final, shall be construed as an acceptance of defective Work or improper materials.

015000 CONSTRUCTION FACILITIES AND TEMPORARY CONTROLS

A. The Contractor is responsible for and shall provide protection of any existing finishes including elevators, lobbies, stairs, and corridors of the base building.

B. The Contractor shall protect existing base building window coverings.

C. The Contractor shall patch and repair fireproofing damaged or removed during performance of the Work. Fireproof non penetrations required by the Work.

D. Debris shall be removed from the site on a daily basis. Upon completion of the Work, remove debris from the site created by the Work provided under the Contract and leave areas clean.

E. The Contractor shall be required to maintain a job site telephone and fax machine.

017700 CLOSEOUT PROCEDURES

A. When the Contractor considers that the Work is substantially complete, the Contractor shall prepare and submit to the Owner a list of items to be completed or corrected. The Owner shall visit the site to determine the status of completion and amend the Contractor's list as required. Upon the Contractor's stated completion of the items listed to be completed or corrected, and prior to final payment, the Architect shall perform a final inspection of all items listed. Failure to complete listed items, as determined by the Architect, shall require additional site visits as needed by the Owner to determine final completion. The cost of any additional site visits shall be billed hourly based on the Owner's published hourly rates and shall be deducted from the Contractor's final payment.

- B. The following items shall be submitted to the Owner by the Contractor before requesting final payment:
1. Complete release or waiver of liens - documentation shall be notarized and signed.
  2. Certificates of inspection approvals for required occupancy permit and similar approvals or certifications by governing authorities, assuring the Owner's full access and use of completed Work.
  3. A notebook containing warranties, bonds, guarantees, affidavits and certificates required by the Contract Documents. Include any operating and cleaning instructions for appliances, materials, finishes, system and equipment installed as part of the Work.

C. Final Cleaning: Remove protective coatings, coverings, and tags, labels or other markings from materials, fixtures and equipment. Clean wall, floor and ceiling surfaces including trim, outlet and switch plates, windows, window sills, and window treatments. Clean plumbing fixtures to a sanitary condition.

DIVISION 3 - CONCRETE

(Note: Refer to structural engineering drawings for complete concrete specifications.)

DIVISION 4 - MASONRY

(Note: Refer to structural engineering drawings for complete masonry specifications.)

042000 UNIT MASONRY ASSEMBLIES

1.01 Summary

- A. This Section includes unit masonry assemblies consisting of the following:
1. Concrete masonry units (CMUs)
  - B. See Division 5 Section "Metal Fabrications for furnishing steel lintels and shelf angles for unit masonry.

1.2 Submittals

- A. Product Data: For each type of product indicated.
- B. Shop Drawings: For reinforcing steel. Detail bending and placement of unit masonry reinforcing bars. Comply with ACI 315, "Details and Detailing of Concrete Reinforcement." Show elevations of reinforced walls.
- C. Material Certificates: For each type of product indicated. Include statements of material properties indicating compliance with requirements including compliance with standards and type designations within standards.
- D. Mix Designs: For each type of mortar and grout. Include description of type and proportions of ingredients.
- 1.3 Quality Assurance

- A. Preconstruction Testing Service: Owner will engage a qualified independent testing agency to perform preconstruction testing indicated below. Payment for these services will be made by Owner.
- a. Clay Masonry Unit Test: For each type of unit required, per ASTM C 67
  - b. Concrete Masonry Unit Test: For each type of unit required, per ASTM C 140
  - c. Mortar Test (Property Spec I) [Cat on]: For each mix required per ASTM C 780
  - d. Grout Test (Compressive Strength): For each mix required, per ASTM C 1019

1.4 Protect Conditions

- A. Cold Weather Requirements: Do not use frozen materials or materials mixed or coated with ice or frost. Do not build on frozen substrates. Remove and replace unit masonry damaged by frost or by freezing conditions. Comply with cold-weather construction requirements contained in ACI 530.1/ASCE/G/TMS 602.
- B. Hot-Weather Requirements: Comply with hot-weather construction requirements contained in ACI 530.1/ASCE/G/TMS 602.

PART 2 - PRODUCTS

- 2.1 Concrete Masonry Units (CMUs)
- A. Shapes: Provide special shape for lintels, corners, jambs, sashes, movement joints, headers, bonding and other special conditions.
- B. Concrete Masonry Units: ASTM C 90
- a. Unit Compressive Strength: Provide units with minimum average net-area compressive length of 1900 psi (13.1 MPa)
  - b. Weight Classification: Standard weight

2.2 MORTAR AND GROUT MIXES

- A. General: Do not use admixtures, unless otherwise indicated.
1. Do not use calcium chloride in mortar or grout.
  2. Limit cementitious materials in mortar for exterior and reinforced masonry to portland cement and lime.
  3. Add cold-weather admixture (if used) at same rate of all mortar that will be exposed to view, regardless of weather conditions, to ensure that mortar color is consistent.
- B. Mortar for Unit Masonry: Comply with ASTM C 270, Proportion Specification.
1. For Masonry below grade or in contact with earth, use Type M or S.
  2. For reinforced masonry, use Type N
  3. For mortar parge coats, use Type S or N.
  4. For exterior, above grade, load bearing partitions; and for other applications where another type is not indicated, use Type
  5. For interior non-load bearing partitions, Type O may be used instead of Type N.

C. Grout for Unit Masonry: Comply with ASTM C 476

1. Use grout of type indicated or, if not otherwise indicated, of type (fine or coarse) that will comply with Table 1.15.1 in ACI 530.1 / ASCE/G/TMS 602 for dimensions of grout spaces and pour height.
2. Provide grout with a slump of 6 to 11 inches (200-280mm) as measured according to ASTM C 143C / 143M.

PART 3 - EXECUTION

3.1 INSTALLATION, GENERAL

- A. Use full-size units without cutting if possible. If cutting is required, cut units with motor-driven saws; provide clean, sharp, unchipped edges. Allow units to dry before laying unless wetting of units is specified. Install cut units with cut surfaces and, where possible, cut edges concealed.
- B. Select and arrange units for exposed unit masonry to produce a uniform blend of colors and textures.
- C. Wetting of Brick: Wet brick before laying if initial rate of absorption exceeds 30g/30 sq. in. (30g/194 sq. cm) per minute when tested per ASTM C 67. Allow units to absorb water so they are damp but not wet at the time of laying.
- D. Comply with tolerances in ACI 530.1 / ASCE/G/TMS 602 and with the following:
1. For conspicuous vertical lines, such as external corners, door jambs, reveals and expansion and control joints, do not vary from plumb by more than 1/8 inch in 10 feet (3mm in 3m), 1/4 inch in 20 feet (6mm in 6m), or 1/2 inch (12mm) maximum.
  2. For conspicuous horizontal lines, such as lintels, sills, parapets, and reveals; do not vary from level by more than 1/8 inch in 10 feet (3 mm in 3 m), 1/4 inch in 20 feet (6 mm in 6 m), or 1/2 inch (12 mm) maximum.

3.2 CLEANING

A. In-Progress Cleaning: Clean unit masonry as work progresses by dry brushing to remove mortar fins and smears before tooling joints.

- B. Final Cleaning: After mortar is thoroughly set and cured, clean exposed masonry as follows:
1. Test cleaning methods on sample wall panel; leave one-half of panel uncleaned for comparison purposes
  2. Protect adjacent surfaces from contact with cleaner.
  3. Wet wall surfaces with water before applying cleaners; remove cleaners promptly; rinse surfaces thoroughly with clear water.
  4. Clean concrete masonry by cleaning in method indicated in NCMA TEK 6-2A applicable 1 type of stain on exposed surfaces.

3.3 MASONRY WASTE DISPOSAL

- A. Waste Disposal as Fill Material: Dispose of clean masonry waste, including excess or soil - contaminated sand, waste mortar, and broken masonry units, by crushing and mixing with fill material as fill is placed.
1. Do not dispose of masonry waste as fill within 1 1/8 inches (450 mm) of finished grade.
  2. Remove excess clean masonry waste that cannot be used as fill, as described above, as other masonry waste, and legally dispose of off Owner's property.

042350 THIN BRICK INSTALLATIONS

PART 1 - GENERAL

1.01 DESCRIPTION

A. Provide all labor and materials necessary to install the BrickFast Panels and accessories which include moisture barriers, fasteners, adhesive, brick mortar, and sealants.

1.02 WORK INCLUDES

- A. BrickFast panel for mechanical attachment of brick mortar to tabs designed to fall within the mortar joint.
- B. Panel provides for a mechanical attachment of brick mortar to tabs designed to fall within the mortar joint.
- C. Adhesive is polyurethane base and recommended for brick.
- D. Flashing
- E. Mortar

1.03 QUALITY ASSURANCE

A. Contractor should be recommended by the local distributor and follow manufacturers' details and application instructions.

1.04 SUBMITTALS

A. Samples: The contractor shall, before the project commences, provide the owner or the architect, a sample of suitable size of each color and texture of the thin brick as specified for the project for the purpose of obtaining approvals. An approved sample of colored mortar must be included in field panel. An approved sample shall be available and maintained at the job site.

1.05 PRODUCTS, DELIVERY, STORAGE, AND HANDLING

A. All materials as well as accessories shall be properly marked and labeled along with MSDS for each product.

B. Store all products, panels and accessories in a cool dry place, above the ground and protected from weather and other damage.

1.06 JOB SITE CONDITIONS

- A. The panels must be clean and free of any foreign matter before installing thin brick.
- B. Mortar must not be applied when temperatures drop below 32 degrees Fahrenheit before initial cure.
- C. Coordination and scheduling is required with related sections and trades.

PART 2 - PRODUCTS

2.01 MANUFACTURERS

A. All products shall be obtained from or approved by the local distributor. Any substitutions must be approved in writing by the manufacturer.

2.02 MATERIALS


- A. Moisture Barrier: Grade D Building Paper, 15 lb. Felt or Tyvek products are recommended over cement backer board.
- B. Starter angle and flashing: Must be galvanized steel or aluminum, and shall be continuous for starter course. All doors and window heads must be properly flashed. Consult local codes for proper roof flashing requirements.
- C. Support Panel: Mechanical support and spacer panel to be 26 gauge architectural grade steel, hot dipped galvanized to G-60. Punched tabs provide a mechanical lock of thin brick with a dovetail back. Another row of punched tabs fall within the mortar joint that lock mortar to the panel.
1. Corner pieces provide a support ledge for corner pieces and spacing of joints that easily line up with standard 2' x 4' and 4' x 4' panels.
- D. Adhesive: Adhesive to be Polyurethane base, sub flooring compatible with bonding brick tile to metal. Adhesives to comply with local building codes and must be ASTM tested.
- E. Mortar: Provide factory blended mortar by A.W. Cook Cement Products and Brick Set by United Products. Mortar can be gray, white, or factory colored. Field mix mortar must be latex modified. Add 1 quart per 80 lb. bag of type S mortar. Call manufacturer for recommendations.
1. Fill any voids in joints with newly struck mortar in order to provide uniform color.
- F. Fasteners: All fasteners must be rust resistant, galvanized or zinc coated.
1. Self-tapping, cadmium plated screws or Versapin fastening system by Aerosmith or similar may be used to fasten panels to the substrate and into light gauge steel framing
  2. Twist-shank masonry nails (cadmium-plated), or fastening system such as TrakFast by Ramset are recommended for fastening panels over concrete or masonry.
- G. Thin Brick: TBX and TBS grade brick with dovetail or groove-back channels as manufactured by McNear Brick and Block, using products recommended with the patented design of the Brickfast panel. Sizes 2-1/4" x 7-5/8".

PART 3 - EXECUTION

- A. Installer must examine conditions under which brick panels are to be installed; substrate must be smooth, sound, and level, and without projections. Any unsatisfactory conditions of the substrate must be corrected before beginning installation of the thin brick panels.
- B. Consult with other trades prior to installing panels to avoid potential interference.
- C. Weather requirements: Do not install mortar when ambient temperature is below 35°F without protection and supplemental heat.
- D. Do not apply mortar to frozen surfaces.

3.02 PREPARATION

- A. Panel layout: Line-up on wall, establishing bottom of lowest panel course and mark level horizontal line at this point.
1. Lay out brick panels at corners working to the center of the wall.
- B. Brick Installation: Manufacturer must be notified in writing of the specified brick to be installed. Panels vary from manufacturer to manufacturer.
1. Apply dime-size dab of adhesive on each tab that dovetail back bricks locks onto.
  2. Run a single course of brick horizontally along the top brick track of the panel beginning at outside corners with corner brick moving inward. Head joint size shall be #1.
  3. Successive rows of brick can now be applied working from the top of the wall down.
- C. Cleaning: Thin brick shall be cleaned by the appropriate method established by The Brick Institute of America. Sure Nlean 600 and Sure Nlean Vana Trol.
1. Brush mortar with a stiff bristle brush using diagonal strokes.
  2. Do not apply cleaning solution until waiting 48 hours after grouting.



L2M ARCHITECTS

1221 811 Cromwell Park Drive, Suite 113  
Cromwell Business Park at BWI  
Glen Burnie, Maryland 21061

L2M@L2M.com  
Phone: 410.863.1302  
Fax: 410.863.1308

I certify that these documents were prepared or approved by me, and that I am a duly licensed architect under the laws of the state of Maryland Lic. #828 Exp.: 07 December 2017.



**DASH IN**

STORE #079

QUARTERFIELD RD - SEVERN, MD

REV. #	ISSUE / DESCRIPTION	DATE

SHEET TITLE:

**GENERAL SPECIFICATION**

DRAWING DATE:  
**01 APRIL 2017**

DRAWN BY: **STAFF**      REVIEWED BY: **SDL**

PROJECT #:  
**15.108**

SHEET #:  
**G-003**

FILE NAME:  
**15.108 - G003.dwg**