



1 FLOOR PLAN - MECHANICAL
S 1/4" = 1'-0"

GENERAL NEW WORK NOTES:

1. REFER TO FOOD SERVICE CONSULTANT DRAWINGS FOR MATERIALS, SPECIFICATION, CAPACITY AND INSTALLATION REQUIREMENTS FOR: ICE MAKER UNIT, REFRIGERATED MERCHANDISE, MAKE-UP AIR SYSTEM, KITCHEN EXHAUST SYSTEM, KITCHEN HOOD, HOOD CONNECTIONS, HOOD FIRE SUPPRESSION SYSTEM, CONTROLS, INTERLOCKS AND SHUT-OFF SWITCHES/VALVES.
2. FIELD COORDINATE FINAL EQUIPMENT LOCATIONS WITH OWNER, EQUIPMENT SUPPLIER AND VENDOR.
3. FIELD COORDINATE AIR DEVICES LOCATION WITH CEILING DEVICES, CEILING FEATURES, MILLWORK AND FLOOR EQUIPMENTS.
4. PROVIDE LOCKABLE COVER FOR THERMOSTAT.

NEW WORK PLAN NOTES: #

1. FIELD COORDINATE WITH KITCHEN HOOD MANUFACTURER REPRESENTATIVE FOR CONNECTION TO KITCHEN HOOD.
2. 3" CONCENTRIC VENT UP THROUGH ROOF. PROVIDE EXHAUST ADAPTOR RING AND INTAKE CAP AS REQUIRED.
3. PROVIDE REFRIGERANT PIPING TO OUTDOOR CONDENSING UNIT ON ROOF.
4. CONNECT 1" CONDENSATE DRAIN LINE TO EVAPORATOR WITH P-TRAP.
5. PROVIDE HEAT TRACE FOR CONDENSATE DRAIN PIPING IN WALK-IN FREEZER. REFER TO ELECTRICAL DRAWINGS FOR HEAT TRACE DETAILS.
6. DISCHARGE CONDENSATE DRAIN PIPING INTO OPEN SITE DRAIN. REFER TO PLUMBING DRAWINGS FOR ADDITIONAL INFORMATION.
7. 12"x12" TRANSFER AIR DUCT WITH 1" SOUND LINING.

m
L2M
811 Cromwell Park Drive, Suite 113
Cromwell Business Park at BWI
Glen Burnie, Maryland 21061
L2M@L2M.com
Phone: 410.863.1302
Fax: 410.863.1308

BR
ENGINEERING SERVICES
502 MC Dr
S M
G Dr, Md 21081
P 410 761-9600
F 410 761-9600
www.br

STATE OF MARYLAND
Professional Engineer
Walter J. Dan
5/10/2017
17 AN 2012



DASH IN
STORE #079
QUARTERFIELD RD - SEVERN, MD

REV. #	ISSUE / DESCRIPTION	DATE
1	OWNER COMMENTS	05/01/17

SHEET TITLE:
FLOOR PLAN MECHANICAL

DRAWING DATE:
01 APRIL 2017
DRAWN BY: MVM
REVIEWED BY: MGH
PROJECT # 2889
SHEET #

M-101
FILE NAME:
2889 - M-101.dwg