



18076069

REVIEWED FOR COMPLIANCE

Symbol	Description/Area	Manufacturer	Specification	Supply	By/Inst	CSCT	OSCI	OSOI
BAR-L-01	Bar Pendant	Restoration Hardware	Item # R1-Clemis Prismatic Single Pendant	X				
BAR-L-02	Bar Pendant	Urban Electric	Item # UE-9400 Metro Scence	X				
BAR-L-03	Wall Scence	Urban Electric	Item # UE-9400 Metro Scence	X				
BAR-L-04	Outdoor Scence	Hallmark Lighting	Item # HLM-120V Candelabra Sockets	X				
BAR-L-05	Host Desk Pendant	Apparatus	Item # A-6005 Host Desk Pendant	X				
BAR-L-06	Custom Chandelier	Hallmark Lighting	Item # HLM-120V Candelabra Sockets	X				
BAR-L-07	Picture Light	Troy Lighting	Item # TL-120V Picture Light	X				
BAR-L-08	Raw Bar Pendant	Apparatus	Item # A-6005 Raw Bar Pendant	X				
BAR-L-09	Restroom Hallway Pendant	Urban Electric	Item # UE-9400 Metro Scence	X				

Performance of this review does not relieve the applicant from full responsibility to comply with all applicable codes, ordinances and regulations.

10/20/19

ITEM NO	QTY	EQUIPMENT CATEGORY	PLUG	DIRECT	VOLTS	PHASE	CYCLE	AMPS	KW	HP	NEMA	ELECTRICAL AFF. (IN)	ELEC REMARKS
A1	1	BAKERY CASE, REFRIGERATED	X	X	120	1	60	16.0		3/4	5-20P	18	
A3	1	DELI CASE, REFRIGERATED	X	X	115	1	60	15.6			5-15P	18	
A4.2	2	DROP-IN, SOUP WELLS	X	X	120	1	60	4.2	0.5		5-15P	18	
A4.3	2	REFRIGERATOR, PIZZA PREP	X	X	115	1	60	10.0		1/4	5-15P	18	
A4.4	2	BUFFET/CAFETERIA, HOT FOOD-SOUP STATION	X	X	208	1	60	15.0			14-20P	18	
A4.5	2	REFRIGERATOR, PIZZA PREP	X	X	115	1	60	12.0		1/3	5-15P	18	
A5	1	EXHAUST HOOD	X	X	120	1	60	11.0			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A5.1	1	EXHAUST HOOD	X	X	120	1	60	11.0			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A5.2	1	EXHAUST HOOD	X	X	120	1	60	11.0			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A5.3	1	EXHAUST HOOD	X	X	120	1	60	11.0			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A5.5	1	EXHAUST FAN	X	X	208-230	1	60	7.4			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A5.6	1	MAKE-UP AIR SYSTEM	X	X	208	3	60	30.0			DN	18	VERIFY WITH MANUFACTURER'S DRAWINGS
A8	1	RANGE, RESTAURANT, GAS			115	1	60	4.0				24	
A9	1	OVEN, CONVECTION, GAS			120	1	60	9.0		1/2		17	
A16	1	OVEN, CONVECTION/COMBI-OVEN, GAS			115	1	60	212.0			2)5-15P	18	
A17	1	RANGE, RESTAURANT, GAS			115	1	60	4.0				24	
A18	1	FRYER, PRESSURE GAS W/ FILTER	X	X	120	1	60	9.6	1.2		5-15P	18	
A19.1	1	EQUIPMENT STAND, REFRIGERATED BASE	X	X	115	1	60	10.0			5-15P	18	
A20.2	2	DROP-IN, SOUP WELLS	X	X	120	1	60	4.2	0.5		5-15P	18	
A20.3	2	REFRIGERATOR, PIZZA PREP	X	X	115	1	60	10.0		1/4	5-15P	18	
A20.4	2	BUFFET/CAFETERIA, HOT FOOD-SOUP STATION	X	X	208	1	60	15.0			14-20P	18	
A20.5	2	REFRIGERATOR, PIZZA PREP	X	X	115	1	60	12.0		1/3	5-15P	18	
A20.6	1	DROP-IN, COLD WELL	X	X	115	1	60	5.0	0.6		5-15P	18	
A22	4	REFRIGERATOR, SANDWICH/SALAD PREP			115	1	60	12.0	1.4	1/2	5-15P	18	
A30	1	WAREWASHER, RACK CONVEYOR	X	X	480	3	60	27.9	15.0	2 1/6		72	
B02	4	BACK BAR EQUIPMENT	X	X	120	1	60	6.3		1/3	5-15P	18	
B08	2	GLASSWASHER	X	X	120	1	60	5.4	0.6		5-15P	18	
B09	2	POS SYSTEM	X	X	120	1	60	5.0			5-15P	18	DEDICATED CIRCUIT AND CONDUIT FOR DATA. VERIFY UTILITIES
B10	1	DISPENSING KIT, BACK BAR & DIRECT DRAW	X	X	115	1	60	12.0	1.4	1/2	5-15P	18	
B15	1	SODA, ICE & BEVERAGE DISPENSER	X	X	115	1	60	10.0			5-15P	48	
B16	1	COFFEE MAKER	X	X	120	1	60	15.4				54	
B18	1	ICE TEA BREWER	X	X	120	1	60	15.4				54	
B19	4	POS SYSTEM	X	X	120	1	60	5.0			5-15P	48	DEDICATED CIRCUIT AND CONDUIT FOR DATA. VERIFY UTILITIES

ITEM NO	QTY	EQUIPMENT CATEGORY	PLUG	DIRECT	VOLTS	PHASE	CYCLE	AMPS	KW	HP	NEMA	ELECTRICAL AFF. (IN)	ELEC REMARKS
LB-03	1	GLASSWASHER	X	X	120	1	60	5.4	0.6		5-15P	18	
LB-05	1	DISPENSER, BEER	X	X	120	1	60	6.3		1/3	5-15P	18	
LB-11	2	BACK BAR EQUIPMENT	X	X	120	1	60	5.5		1/4	5-15P	18	
LB-12	2	POS SYSTEM	X	X	120	1	60	5.0			5-15P	18	DEDICATED CIRCUIT AND CONDUIT FOR DATA. VERIFY UTILITIES
LB-16	1	SODA, ICE & BEVERAGE DISPENSER	X	X	115	1	60	10.0			5-15P	48	
LB-17	1	COFFEE MAKER, AIRPOT, AUTOMATIC	X	X	120	1	60	15.4				54	
RB-07	1	BACK BAR EQUIPMENT	X	X	120	1	60	6.3		1/3	5-15P	18	
RB-08	2	POS SYSTEM	X	X	120	1	60	5.0			5-15P	18	DEDICATED CIRCUIT AND CONDUIT FOR DATA. VERIFY UTILITIES
RB-13	1	ICE MAKER	X	X	208-230	1	60	15.4				84	

KITCHEN EQUIPMENT SCHEDULES SHOWN FOR REFERENCE ONLY, COORDINATE ALL CONNECTIONS WITH KITCHEN EQUIPMENT DRAWING PRIOR TO ROUGH IN.

ITEM NO	QTY	EQUIPMENT CATEGORY	PLUG	DIRECT	VOLTS	PHASE	CYCLE	AMPS	KW	HP	NEMA	ELECTRICAL AFF. (IN)	ELEC REMARKS
P1.1	1	WALK-IN COOLER	X	X	115	1	60	1.8				18	SEE MANUFACTURE SHOP DRAWINGS
P1A	2	WALK-IN COOLER EVAPORATOR	X	X	115	1	60	1.8				18	SEE MANUFACTURE SHOP DRAWINGS
P1A.1	1	WALK-IN COOLER CONDENSER	X	X	208-230	3	60	9.7		1.5		18	SEE MANUFACTURER DRAWING FOR DETAILS
P1B	1	WALK-IN FREEZER EVAPORATOR	X	X	208-230	3	60	5.0				18	SEE MANUFACTURER SHOP DRAWINGS
P1B.1	1	WALK-IN FREEZER CONDENSER	X	X	208-230	3	60	6.3		2		18	SEE MANUFACTURER DRAWING FOR DETAILS
P10	1	MIXER, BENCH	X	X	120	1	60	11.0		3/4	5-15P	18	
P10A	1	SLICER, FOOD	X	X	115	1	60	7.0		1/2	5-15P	18	
P13	36	WINE CABINET	X	X	115	1	60	4.0	0.5	1/4	5-15P	18	
P22	3	REFRIGERATOR, UNDERCOUNTER, LOW PROFILE	X	X	115	1	60	4.0	0.5	1/4	5-15P	18	
P23	2	CUTTER/MIXER, VERTICAL & VEG. PREP, COMBO	X	X	120	1	60	9.0		1/2	5-15P	48	
P27	1	BAG IN BOX	X	X	120	1	60	8.0		1/3	5-15P	84	

ARCHITECT
HapstakDemetriou + ARCHITECTURE | DESIGN
2715 M STREET NW, 4th Floor
WASHINGTON, DC 20007
202.333.9038
www.hd-ad.com info@hd-ad.com

CLIENT
Alexanader Smith
(410) 241-1224
afsmith11@gmail.com
STRUCTURAL ENGINEER
BEI Structural Engineers
3930 Pender Dr. Suite 175
Fairfax, VA 22030

MEP ENGINEER
J.B. Wyble and Associates, P.A.
7950 Norfolk Ave., Bethesda, MD
301-654-1410
FOOD SERVICE CONSULTANT
JLA Corp
13031 US Highway 19N, Clearwater, FL 33764
727-470-7862

OUZO BAY/ LOCH BAR HOUSTON
4444 WESTHEIMER RD, HOUSTON, TX 77027
PROJECT NO. JBW17108
I CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF TEXAS.
PE. LICENSE #: 129510, EXPIRATION DATE: DECEMBER 31, 2018
FIRM LICENSE #: F19615, EXPIRATION DATE: MARCH 31, 2019

REV	DATE	ISSUED FOR	REV	DATE	ISSUED FOR
05/16/2018	PROGRESS SET				
06/11/2018	PERMIT SET				
08/30/2018	PERMIT COMMENTS				

OUZO BAY/ LOCH BAR ELECTRICAL SCHEDULES
E.02



P:\National Projects\Hapstak Demetriou\OUZO BAY HOUSTON\17-040 ELECTRICAL_SCHEDULES.dwg, 03/20/2018 8:58:31 AM, 3891 DWT, TYP:PDF, PLOT: 3.8, Wyble and Associates, R08