



OUZO BAY SWITCHING/ DIMMING SCHEDULE							
DIM/SWITCH CIRCUIT NUMBER	LOCATION	FIXTURE QUANTITY	FIXTURE TYPE	FIXTURE WATTS	TOTAL WATTS	CONTROL	REMARKS
01	DINING PENDANT	11	D1	11	121	DIMMER	
02	WALL SCONCE	6	B1	2	12	DIMMER	
03	COLUMN LIGHT	12 X 11'	C1	6/FT	792	DIMMER	
04	WALL SCONCE	6	B1	2	12	DIMMER	
05	BAR WORK LTS	6 47'	A3 C5	18 1W/FT	155	DIMMER	
06	BAR PENDANT CLUSTER	60	D4 CLUSTER	2	120	DIMMER	
07	DINING 3 DN LTS	16	A3	18	288	DIMMER	
08	DINING 3 PEND LTS	6	D3	26	156	DIMMER	
09	DINING 3 PEND LTS	6	D2	26	156	DIMMER	
10	DINING 3 DN LTS	4	A2	12	48	DIMMER	
11	DINING 3 DN LTS	5	D2	26	130	DIMMER	
12	DINING 3 PEND LTS	14	D1	11	154	SWITCH	
13	DINING AISLE DN LTS	11	A3	18	198	DIMMER	
14	ENTRY PEND	4	D1	11	44	DIMMER	
14A	EXTER ENTRY PEND	3	D1	11	33	DIMMER	
15	EXTER ENTRY DN LTS	2	A6	18	36	DIMMER	
16	WINE RM DN LTS	8	A1	12	96	DIMMER	
17	PDR RM DN LTS	3	A3	18	54	DIMMER	
18	PDR RM PEND	5	D1	11	55	DIMMER	
19	PDR RM SCONE	2	B2	5	10	DIMMER	
20	PDR RM EXTER WINDOW LTS	4	A1	12	48	DIMMER	
21	HALLWAY LTS	5	A5	15	75	DIMMER	
22	KIT DISPLAY TS	3	D5	60	180	DIMMER	
23	KIT DISPLAY TS	3	A2	12	36	DIMMER	
24	DINING AISLE ACCENT LED	35' 9'	C1 C6	6/FT 3/FT	237	DIMMER	
25	BOOTH ACCENT LED	110' 43'	C3 C4	2/FT 5/FT	435	DIMMER	
26	MAIN DINING ACCENT LED	39' 157'	C4 C6	5/FT 3/FT	666	DIMMER	
27	PRIVATE DINING ACCENT LED	57'	C6	3/FT	171	DIMMER	
28	EXTER FANS	5	-	-	-	SWITCH	
29	EXTER PLANTER LTS	14	X1	20	-	SWITCH	
30	EXTER STRING LTS	21	-	1200	1200	SWITCH	
31	EXTER STRING LTS	21	-	1200	1200	SWITCH	
32	EXTER STRING LTS	21	-	1200	1200	SWITCH	
33	SPARE	-	-	-	-	-	
34	MAIN DIN AISLE LTS	3	A3	18	66	DIMMER	
		1	A1	12			
35	KITCHEN LTS	17	F1	29	493	SWITCH	
36	RESTROOM LTS	4	A1	12	48	SENSOR	
		4	A5	15	60		
		10'	C6	3/FT	30		
					TOTAL		
					138		

OUZO BAY SIMPLIFIED LIGHTING SCHEDULE					
NOTE: SCHEDULE IS FOR COORDINATING LAMP AND FIXTURE WATTAGES ONLY. SEE ARCHITECTURAL FIXTURE SCHEDULES FOR COMPLETE FIXTURE INFORMATION					
FIXTURE ID	LAMP QTY	LAMP WATTAGE	LAMP TYPE	FIXTURE TYPE	REMARKS
A1	1	12W	LED	DOWNLIGHT	
A2	1	12W	LED	SPOT	
A3	1	18W	LED	DOWNLIGHT	
A5	1	15W	LED	WALL WASH	
A6	1	18W	LED	DOWNLIGHT	
B1	1	2W	LED	SCONCE	
B2	1	5	LED	SCONCE	5W MAX LED LAMP
C1	1	6W/FT	LED	WALL GRAZE STRIP	
C2	1	4.5W/FT	LED	EXTER SHEET LED SIGNAGE	
C3	-	1.5W/FT	LED	LED TAPE LIGHT	
C4	-	4.7W/FT	LED	BENDABLE LED STRIP	
C5	-	.8W/FT	LED	BAR WORK ROPE LIGHT	
C6	-	3W/FT	LED	LED TAPE LIGHT	
D1	1	11W	LED	PENDANT	11W MAX LED LAMP
D2	1	26W	LED	BOOTH PENDANT	26 MAX LED LAMP
D3	1	26W	LED	BOOTH PENDANT	26 MAX LED LAMP
D4	1	2W	LED	BAR PENDANT	1.8 MAX LED LAMP
D5	1	60W	INCAN	KITCHEN PENDANT	60W MAX A19
F1	1	29W	LED	KITCHEN 2X4	SHADED IND. 90. MIN BATT
W1	1	25W	LED	MECH RM 1X4	SHADED IND. 90. MIN BATT
X1	1	20W	MR16	EXTER LANDSCAPE SPOT	
X2	50	25W	LED	EXTER STRING LTS	
EX1	2	5W	LED	FOH EXIT LIGHT	W/ 90 MIN BATTERY
EX2	2	5W	LED	BOH EXIT LIGHT	W/ 90 MIN BATTERY
EM1	4	3W	LED	EXTER EGRESS LTS	W/ 90 MIN BATTERY
EM2	2	7W	LED	INTER EMER LTS	W/ 90 MIN BATTERY

NOTE: SOME FIXTURES MAY INCLUDE LAMP HOLDERS OR SOCKETS WHICH ARE CAPABLE OF HIGHER WATTAGES THAN INSTALLED LAMPS. MANUFACTURER TO SUPPLY/ APPLY PROPER MAXIMUM LAMP WATTAGE LABELS AS REQUIRED SO THAT END USER DOES NOT OVERLOAD FIXTURE OR CIRCUIT

LOCH BAR SIMPLIFIED LIGHTING SCHEDULE					
NOTE: SCHEDULE IS FOR COORDINATING LAMP AND FIXTURE WATTAGES ONLY. SEE ARCHITECTURAL FIXTURE SCHEDULES FOR COMPLETE FIXTURE INFORMATION					
FIXTURE ID	LAMP QTY	LAMP WATTAGE	LAMP TYPE	FIXTURE TYPE	REMARKS
A4A1	1	18W	LED	4 INCH DOWNLIGHT	
A4B1	1	18W	LED	4 INCH DOWNLIGHT	
A4C	1	18W	LED	4 INCH DOWNLIGHT	
A5	2	18W	LED	4 INCH DUAL DOWNLIGHT	
C1	-	3W/FT	LED	LED STRIP	
C2	-	3W/FT	LED	LED STRIP	
C3	-	3W/FT	LED	LED STRIP	60W DRIVER
C4	-	3W/FT	LED	LED STRIP	
D4A	1	18W	LED	4 INCH DOWNLIGHT	
D4A1	1	18W	LED	4 INCH DOWNLIGHT	
D4B	1	18W	LED	4 INCH DOWNLIGHT	
D4B1	1	18W	LED	4 INCH DOWNLIGHT	
D4C	1	18W	LED	4 INCH DOWNLIGHT	
TA	1	8W	LED	TRACK HEAD A	50W MAX
TB	1	8W	LED	TRACK HEAD B	50W MAX
BAR-LT-01	2	13W	LED	18 INCH PENDANT	(2) 100W MAX A19
BAR-LT-02	20	135W	LED	CUBE STRING LIGHT	(20) 60W MAX A19
BAR-LT-03	1	60W	LED	WALL SCONCE	(1) 60W MAX A19
BAR-LT-04	2	7W	LED	EXTER WALL SCONCE	(2) E12 SOCKETS
BAR-LT-05	3	72W	LED	HOST PENDANT	(3) G16 SOCKETS (6) G25 SOCKETS
BAR-LT-06	6	72W	LED	BOOTH CHANDELIER	(6) E26 SOCKETS
BAR-LT-07	1	25W	INCAN	PICTURE LIGHT	(1) T10 SOCKET
BAR-LT-08	3	72W	LED	RAW BAR PENDANT	(3) G16 SOCKETS (6) G25 SOCKETS
BAR-LT-09	3	10W	LED	BACK HALL PEND	(3) 60W MAX SOCKET
BAR-LT-10	1	9W	LED	PICTURE LIGHT	

NOTE: SOME FIXTURES MAY INCLUDE LAMP HOLDERS OR SOCKETS WHICH ARE CAPABLE OF HIGHER WATTAGES THAN INSTALLED LAMPS. MANUFACTURER TO SUPPLY/ APPLY PROPER MAXIMUM LAMP WATTAGE LABELS AS REQUIRED SO THAT END USER DOES NOT OVERLOAD FIXTURE OR CIRCUIT

LOCH BAR SWITCHING/ DIMMING SCHEDULE							
DIM/SWITCH CIRCUIT NUMBER	LOCATION	FIXTURE QUANTITY	FIXTURE TYPE	FIXTURE WATTS	TOTAL WATTS	CONTROL	REMARKS
01	ENTRY PENDANT	1	BAR-LT-05	72	72	DIMMER	
02	ENTRY TRACK A	7	TA	8	100	DIMMER	
03	ENTRY TRACK B	4	TB	8	100	DIMMER	
-	-	-	-	-	-	-	
05	DINING BIG PENDANTS	6	BAR-LT-06	72	432	DIMMER	
06	DINING DN LTS L	3	D4B1	18	54	DIMMER	
07	DINING DN LTS C	7	D4A1	18	126	DIMMER	
08	DINING DN LTS R	2	D4B1	18	36	DIMMER	
09	STAGE LTS	2	A5	18	36	DIMMER	TYP. TYPE A2C MULTIPLE DOWNLIGHTS TO BE CROSS-AIMED TO PERFORMANCE AREA.
10	WINDOW STRIP LED EXTERIOR LTS	24' 4	C4 BAR-LT-04	3W/FT 7	100	DIMMER	TYP. TYPE C4 INLAID LED STRIP EXTRUSION LOC ALONG WINDOW SILL TO UPLIGHT CURTAINS. REGS REMOTE POWER SUPPLY.
11	BIG BAR PEND	5	BAR-LT-01	13	65	DIMMER	
12	BIG BAR BOTTLE LTS	7 X 3' 6 X 3'	C3 C3	3W/FT 3W/FT	63 54	SWITCH	TYP. TYPE C3 INLAID LED EOS PANELS TO UPLIGHT BOTTLES. REGS REMOTE POWER SUPPLY. SEE DETAILS. TYP. TYPE C3 INLAID LED EOS PANELS IN 5-TIER UNIT TO UPLIGHT BOTTLES ON BAR COUNTERTOP. REGS REMOTE POWER SUPPLY. SEE DETAILS.
13	BIG BAR DN LTS	4	D4B1	18	72	DIMMER	
14	BIG BAR SCONCES	2	BAR-LT-03	60	120	DIMMER	
-	-	-	-	-	-	-	
16	BIG BAR TOP	35' 22'	C1 C2	3W/FT 3W/FT	105 66	DIMMER	TYP. C1 UNDERCOUNTER LED EXTRUSION STRIP GRAZER INSTALLED ALONG BAR FACE. REGS REMOTE POWER SUPPLY. TYP. C2 WET LOCATION LED UNDERCOUNTER STRIP EXTRUSION LOC. ABOVE BAR SERVICE COUNTER. REGS REMOTE POWER SUPPLY.
17	BIG BAR BOTTLE LTS	3 X 3'	C3	3W/FT	27	SWITCH	TYP. TYPE C3 INLAID LED EOS PANELS TO UPLIGHT BOTTLES. REGS REMOTE POWER SUPPLY. SEE DETAILS.
18	BACK BAR SCONCES	2	BAR-LT-10	9	18	DIMMER	
19	SM BAR TOP	18' 6'	C1 C2	3W/FT 3W/FT	54 18	DIMMER	TYP. C1 UNDERCOUNTER LED EXTRUSION STRIP GRAZER INSTALLED ALONG BAR FACE. REGS REMOTE POWER SUPPLY. TYP. C2 WET LOCATION LED UNDERCOUNTER STRIP EXTRUSION LOC. ABOVE BAR SERVICE COUNTER. REGS REMOTE POWER SUPPLY.
20	SM BAR DN LTS	3	D4A1	18	54	DIMMER	
21	SM BAR PENDANT/SCONCE	2	BAR-LT-07 BAR-LT-08	25 72	122	DIMMER	
22	SM BAR ACCENT DN LTS	2	A4A1 A4B1	18 18	72	DIMMER	
23	SM BAR DN LTS	2	D4B1	18	36	DIMMER	
24	SM BAR DN LTS	3	A4B1	18	54	DIMMER	
25	SIDE BOOTH LTS	4	BAR-LT-02	135	540	DIMMER	
26	BACK HALL	2	BAR-LT-09	10	20	DIMMER	
27	BACK HALL	1 6 3 3	A4C D4B D4C D4A	18 18 18 18	234	DIMMER	
-	-	-	-	-	-	-	
-	-	-	-	-	-	-	

OUZO BAY/LOCH BAR MEZZANINE SWITCHING/ DIMMING SCHEDULE							
DIM/SWITCH CIRCUIT NUMBER	LOCATION	FIXTURE QUANTITY	FIXTURE TYPE	FIXTURE WATTS	TOTAL WATTS	CONTROL	REMARKS
-	KITCHEN LTS	3	F1	29	87	-	
-	KITCHEN & STAIR LTS	8	F1	29	232	-	
-	MECH ROOM LTS	3	W1	25	75	-	
-	HALLWAY LTS	6	W1	25	150	-	
-	OFFICE/BATHROOM LTS	4	A1	18	72	-	

18076069
REVIEWED FOR COMPLIANCE
The issuance of this permit does not relieve the applicant from full responsibility to comply with all applicable codes, ordinances and regulations 10/29/18



F:\Autocad Projects\houston\houston\OUZO BAY/LOCH BAR MEZZANINE SWITCHING SCHEDULES.dwg, 8/21/2018 9:07:48 AM, 18W DWG to PDF.plt, J.B. Wyble and Associates, P.A.

ARCHITECT HapstakDemetriou + ARCHITECTURE DESIGN 2715 M STREET NW, 4th Floor WASHINGTON, DC 20007 202.333.9038 www.hd-ad.com info@hd-ad.com	CLIENT Alexanader Smith (410) 241-1224 afsmith11@gmail.com STRUCTURAL ENGINEER BEI Structural Engineers 3930 Pender Dr. Suite175 Fairfax, VA 22030	MEP ENGINEER J.B. Wyble and Associates, P.A. 7950 Norfolk Ave., Bethesda, MD 301-654-1410 FOOD SERVICE CONSULTANT JLA Corp 13031 US Highway 19N, Clearwater, FL 33764 727-470-7862	OUZO BAY/ LOCH BAR HOUSTON 4444 WESTHEIMER RD, HOUSTON, TX 77027 PROJECT NO. JBW17108 I CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF TEXAS. PE. LICENSE #: 129510, EXPIRATION DATE: DECEMBER 31, 2018 FIRM LICENSE #: F19615, EXPIRATION DATE: MARCH 31, 2019	REV DATE ISSUED FOR - 05/16/2018 PROGRESS SET - 06/11/2018 PERMIT SET - 08/30/2018 PERMIT COMMENTS	REV DATE ISSUED FOR - - - - - - - - -	OUZO BAY/ LOCH BAR LIGHTING & SWITCHING SCHEDULES E.14
				- - - - - - - - -	- - - - - - - - -	