



18076069

REVIEWED FOR COMPLIANCE

Performance of this review does not relieve the applicant from full responsibility to comply with all applicable codes, ordinances and regulations 10/29/18

PLUMBING ROUGH-IN SCHEDULE													
ITEM NO	QTY	EQUIPMENT CATEGORY	COLD WATER SIZE (IN)	COLD WATER AFF (IN)	HOT WATER SIZE (IN)	HOT WATER AFF (IN)	DIRECT DRAIN SIZE (IN)	DIRECT DRAIN AFF (IN)	INDIR DRAIN SIZE (IN)	GAS SIZE (IN)	MBTUH	GAS AFF (IN)	PLUMBING REMARKS
A2	1	HAND SINK, WALL MOUNT	1/2	12	1/2	12	1	1/2	20				
A4	1	CHEFS COUNTER W/OVERSHLF & SINK	1/2	12	1/2	12				1 1/2			
A4.1	2	HAND SINK	1/2	12	1/2	12	1	1/2	20				
A6	3	FRYER, DEEP FAT, GAS								3/4	110	18	
A7	1	BROILER, UNDER-FIRED, GAS, FLOOR MODEL								3/4	72	12	
A8	1	RANGE, RESTAURANT, GAS								3/4	215	12	
A9	1	OVEN, CONVECTION, GAS								3/4	88	12	
A10	1	BROILER, UNDER-FIRED/GAS								1	252	12	
A16	1	OVEN, CONVECTION/COMBI-OVEN, GAS								(2)3/4	180	12	
A17	1	RANGE, RESTAURANT, GAS								3/4	275	12	
A18	1	FRYER, PRESSURE GAS W/ FILTER								3/4	80	12	
A19	1	BROILER, UNDER-FIRED, GAS, COUNTER								3/4	144	12	
A20	1	CHEFS COUNTER W/OVERSHLF & SINK	1/2	12	1/2	12				1 1/2			
A20.1	2	HAND SINK	1/2	12	1/2	12	1	1/2	20				
A27	1	3 COMP. SINK								(3)1-1/2			
A27.1	1	PRE-RINSE FAUCET, WALL MOUNT	1/2	18	1/2	18							
A30	1	WAREWASHER, RACK CONVEYOR								2			
A31.2	1	PRE-RINSE FAUCET, WALL MOUNT	1/2	18	1/2	18							
B03	2	UNDERBAR DRY STORAGE								1 1/2			
B04	2	UNDERBAR COCKTAIL STATION	(3)1/2	12	1/2	12				(5)1/2			
B05	2	UNDERBAR DRY WASTE	1/2	12	1/2	12				1-1/2			
B06	3	UNDERBAR HANDSINK	3/8	13	3/8	13				1 1/2			
B07	1	UNDERBAR ALL-IN-ONE STATION	3/8	12	3/8	12				(3)1-1/2			
B08	2	GLASSWASHER								1 1/4			
B10	1	DISPENSING KIT, BACK BAR & DIRECT DRAW								1/2			
B14	1	BEVERAGE COUNTER W/SINK	1/2	12	1/2	12				1 1/2			
B15	1	SODA, ICE & BEVERAGE DISPENSER	3/4	48						3/4			
B16	1	COFFEE MAKER	1/2	42						1/2			
B18	1	ICE TEA BREWER	1/2	42						1/2			


PLUMBING FIXTURE SCHEDULE							
NO.	DESCRIPTION	SOIL	W.	V.	C.W.	H.W.	REMARKS
P-1	WATER CLOSET (HC)	4"	-	2"	1"	-	FLOOR MOUNTED FLUSH VALVE, SEE ARCHITECTURAL DRAWINGS FOR MORE INFORMATION
P-2	WATER CLOSET	4"	-	2"	1"	-	FLOOR MOUNTED FLUSH VALVE, SEE ARCHITECTURAL DRAWINGS FOR MORE INFORMATION
P-3	LAVATORY (HC)	-	1-1/2"	1-1/2"	1/2"	1/2"	UNDERCOUNTER MOUNTED, SEE ARCHITECTURAL DRAWINGS FOR MORE INFORMATION
P-4	LAVATORY	-	1-1/2"	1-1/2"	1/2"	1/2"	WALL MOUNTED, SEE ARCHITECTURAL DRAWINGS FOR MORE INFORMATION

FLOOR DRAIN SCHEDULE					
NO.	MFG.	MODEL NO.	ACCESSORIES	FREE AREA	REMARKS
FS-1	SIoux CHIEF	861-23	-	22 SQ IN	
FD-1	SIoux CHIEF	832-36PNQ	-	8 SQ IN	
FD-2	SIoux CHIEF	832-2PNQ	-	8 SQ IN	

PLUMBING EQUIPMENT ROUGH-IN SCHEDULE													
ITEM NO	QTY	EQUIPMENT CATEGORY	COLD WATER SIZE (IN)	COLD WATER AFF (IN)	HOT WATER SIZE (IN)	HOT WATER AFF (IN)	DIRECT DRAIN SIZE (IN)	DIRECT DRAIN AFF (IN)	INDIR DRAIN SIZE (IN)	GAS SIZE (IN)	MBTUH	GAS AFF (IN)	PLUMBING REMARKS
P1A	2	WALK-IN COOLER EVAPORATOR											
P1B	1	WALK-IN FREEZER EVAPORATOR											
P08	1	TABLE PREP W/ SINK								1-1/2			
P11	1	MOP SINK	1/2	12	1/2	12	3						
P12	2	HAND SINK, WALL MOUNT	1/2	12	1/2	12	1	1/2	20				
P17	1	SINK, SCULLERY, 3 COMPARTMENTS								(3)1-1/2			
P19	2	FAUCET, WALL MOUNT, WITH PRE-RINSE	1/2	12	1/2	12							
P27.1	1	FILTER SYSTEM	3/4	60									

PLUMBING EQUIPMENT ROUGH-IN SCHEDULE													
ITEM NO	QTY	EQUIPMENT CATEGORY	COLD WATER SIZE (IN)	COLD WATER AFF (IN)	HOT WATER SIZE (IN)	HOT WATER AFF (IN)	DIRECT DRAIN SIZE (IN)	DIRECT DRAIN AFF (IN)	INDIR DRAIN SIZE (IN)	GAS SIZE (IN)	MBTUH	GAS AFF (IN)	PLUMBING REMARKS
LB-01	1	UNDERBAR COCKTAIL STATION	(3)1/2	12	1/2	12				(4)1-1/2			
LB-03	1	GLASSWASHER								1 1/4			
LB-04	1	UNDERBAR HANDSINK	3/8	13	3/8	13				1 1/2			
LB-05	1	DISPENSER, BEER								(2)			
LB-06	2	UNDERBAR DRY STORAGE								1			
LB-09	1	UNDERBAR COCKTAIL ICE CHEST								1/2			
LB-10	1	UNDERBAR COCKTAIL STATION	(3)1/2	12	1/2	12				(4)1-1/2			
LB-16	1	SODA, ICE & BEVERAGE DISPENSER	3/4	48						3/4			
LB-17	1	COFFEE MAKER, AIRPOT, AUTOMATIC	1/2	42						1/2			
LB-18	1	HAND SINK	1/2	12	1/2	12	1	1/2	20				
RB-01	1	ICE BIN FOR SHELLFISH								1-1/2			
RB-04	1	UNDERBAR HANDSINK	3/8	13	3/8	13				1 1/2			
RB-05	1	UNDERBAR COCKTAIL ICE CHEST								1/2			
RB-12	1	DROP-IN, WATER & ICE STATION	1/2	18						1			
RB13	1	ICE MAKER	1/2	72									
RB-13.1	1	ICE BIN								1			
RB-13.2	1	WATER FILTER SYSTEM	3/8	72									
RB-13.3	1	FLOOR TROUGH								3	0		

NOTE:
COORDINATE ALL FIXTURE LOCATIONS, TYPES, CONNECTION SIZES, ETC. WITH FS DRAWINGS PRIOR TO ROUGH-IN.



ARCHITECT HapstakDemetriou + ARCHITECTURE DESIGN 2715 M STREET NW, 4th Floor WASHINGTON, DC 20007 202.333.9038 www.hd-ad.com info@hd-ad.com	CLIENT Alexanader Smith (410) 241-1224 afsmith11@gmail.com STRUCTURAL ENGINEER BEI Structural Engineers 3930 Pender Dr. Suite175 Fairfax, VA 22030	MEP ENGINEER J.B. Wyble and Associates, P.A. 7950 Norfolk Ave., Bethesda, MD 301-654-1410 FOOD SERVICE CONSULTANT JLA Corp 13031 US Highway 19N, Clearwater, FL 33764 727-470-7862	OUZO BAY/ LOCH BAR HOUSTON 4444 WESTHEIMER RD, HOUSTON, TX 77027 PROJECT NO. JBW17108	REV DATE ISSUED FOR 05/16/2018 PROGRESS SET 06/11/2018 PERMIT SET 08/30/2018 PERMIT COMMENTS	REV DATE ISSUED FOR _____ _____ _____	PLUMBING SCHEDULES P.02
				I CERTIFY THAT THESE DOCUMENTS WERE PREPARED OR APPROVED BY ME, AND THAT I AM A DULY LICENSED PROFESSIONAL ENGINEER UNDER THE LAWS OF THE STATE OF TEXAS. P.E. LICENSE #: 129510, EXPIRATION DATE: DECEMBER 31, 2018 FIRM LICENSE #: F19615, EXPIRATION DATE: MARCH 31, 2019		