

# COMcheck Software Version 3.9.2 Interior Lighting Compliance Certificate

## 2010 New York Energy Conservation Construction Code

### Section 1: Project Information

Project Title: Lifeline Access Center  
Construction Site: 1733 Eastchester Road, Bronx, NY 10461  
Owner/Agent: Lifeline Access Center  
Designer/Contractor: Richard J. Stem, P.E., 2741 Furnace Road, Felton, PA 17522

### Section 2: Interior Lighting and Power Calculation

Area Category	Floor Area (sq ft)	Allowed Watts (ft <sup>2</sup> )	Allowed Watts (W/C)
Exam/Treatment (Hospital)	6635	1.2	7962
Total Allowed Watts =			7962

### Section 3: Interior Lighting Fixture Schedule

Fixture ID	Description / Lamp / Wattage Per Lamp / Ballast	Lamps / Fixture	# of Fixtures	C (Watt)	D (Watt)	E (Watt)
Exam/Treatment (Hospital) 6635 sq ft						
Linear Fluorescent 1: A: 2x4 Fluor. 48" T8 32W Electronic		2	68	64	4352	
Linear Fluorescent 2: A1: 2x4 Fluor. 48" T8 32W Electronic		4	18	128	2304	
Linear Fluorescent 3: B: 2x4 Fluor. 48" T8 32W Electronic		3	2	96	192	
Compact Fluorescent 1: D: Fluor Down Light Triple 4-pin 20W Electronic		2	6	52	312	
Incandescent 1: G: Operating Light Head/Headset 250W		1	2	250	500	
Compact Fluorescent 2: H: Fluor Down Light Triple 4-pin 20W Electronic		1	1	26	26	
Total Proposed Watts =					7686	

### Section 4: Requirements Checklist

- Lighting Wattage:**
  - 1. Total proposed watts must be less than or equal to total allowed watts.
- Allowed Watts Proposed Watts Compiles**

7962	7686	YES
------	------	-----
- Controls, Switching, and Wiring:**
  - 2. Daylight zones under skylights more than 15 feet from the perimeter have lighting controls separate from daylight zones adjacent to vertical fenestration.
  - 3. Daylight zones have individual lighting controls independent from that of the general area lighting.
  - 4. Contiguous daylight zones spanning no more than two orientations are allowed to be controlled by a single controlling device.
  - 5. Daylight spaces enclosed by walls or ceiling height partitions and containing two or fewer light fixtures are not required to have a separate switch for general area lighting.

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 1 of 2

# COMcheck Software Version 3.8.1 Mechanical Compliance Certificate

## 2009 IECC

### Section 1: Project Information

Project Title: Lifeline Access Center  
Construction Site: 1733 Eastchester Road, Bronx, NY 10461  
Owner/Agent: Lifeline Access Center  
Designer/Contractor: Richard J. Stem, P.E., 2741 Furnace Road, Felton, PA 17522

### Section 2: General Information

Building Location (or weather data): Bronx, New York  
Climate Zone: 4a

### Section 3: Mechanical Systems List

Quantity	System Type & Description
1	HVAC System RTU-1 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-2 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-3 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 12000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 9000 kBtu/h, Efficiency = 11.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: High Efficiency Equipment
1	HVAC System RTU-4 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 7200 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 3600 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: Filtration Requirements
1	HVAC System EDH-1 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EDH-2 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-3 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-4 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-5 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EWH-1 (Single Zone): Heating: 1 each - Unit Heater, Electric, Capacity = 6826 kBtu/h
1	HVAC System HUH-1 (Single Zone): Heating: 1 each - Unit Heater, Electric, Capacity = 10239 kBtu/h
1	Water Heater WH-1: Electric Storage Water Heater, Capacity: 100 gallons w/ Circulation Pump, Efficiency: 98.00

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 1 of 2

### Section 4: Requirements Checklist

- Requirements Specific To: HVAC System RTU-1:**
  - 1. Equipment minimum efficiency: Central Furnace (Gas): 80.0 % EER
  - 2. Equipment minimum efficiency: Rooftop Package Unit: 9.5 EER (9.2 IPLV)
  - 3. Discharge dampers prohibited with fan motors > 10 hp
- Requirements Specific To: HVAC System RTU-2:**
  - 1. Equipment minimum efficiency: Central Furnace (Gas): 80.0 % EER
  - 2. Equipment minimum efficiency: Rooftop Package Unit: 9.5 EER (9.2 IPLV)
  - 3. Discharge dampers prohibited with fan motors > 10 hp
- Requirements Specific To: HVAC System RTU-3:**
  - 1. Equipment minimum efficiency: Central Furnace (Gas): 80.0 % EER
  - 2. Equipment minimum efficiency: Rooftop Package Unit: 9.5 EER (9.2 IPLV)
  - 3. Discharge dampers prohibited with fan motors > 10 hp
  - 4. Discharge dampers prohibited with fan motors > 10 hp
  - 5. Integrated air economizer required
- Requirements Specific To: HVAC System RTU-4:**
  - 1. Equipment minimum efficiency: Central Furnace (Gas): 80.0 % EER
  - 2. Equipment minimum efficiency: Rooftop Package Unit: 9.5 EER (9.2 IPLV)
  - 3. Cooling system provides a means to relieve excess outdoor air during economizer operation.
  - 4. Discharge dampers prohibited with fan motors > 10 hp
  - 5. Integrated air economizer required
- Requirements Specific To: HVAC System EDH-1:**
  - None
- Requirements Specific To: HVAC System EDH-2:**
  - None
- Requirements Specific To: HVAC System EDH-3:**
  - None
- Requirements Specific To: HVAC System EDH-4:**
  - None
- Requirements Specific To: HVAC System EDH-5:**
  - None
- Requirements Specific To: HVAC System EWH-1:**
  - None
- Requirements Specific To: HVAC System HUH-1:**
  - None
- Requirements Specific To: Water Heater WH-1:**
  - 1. Electric Water Heater efficiency: 0.8 EF (270 SL, Bluh (if > 12 kW))
  - 2. All piping in circulating system insulated
  - 3. Hot water storage temperature adjustable down to 120°F or lower
  - 4. Automatic time control of heat tapes and recirculating systems present
  - 5. Controls will shut off operation of circulating pump between water heater/boiler and storage tanks within 5 minutes after end of heating cycle
- Generic Requirements: Must be met by all systems to which the requirement is applicable:**
  - 1. Plant equipment and system capacity no greater than needed loads
    - Exception: Standby equipment automatically off when primary system is operating
    - Exception: Multiple units controlled to sequence operation as a function of load
  - 2. Minimum one temperature control device per system
  - 3. Minimum one humidity control device per installed humidification/dehumidification system
  - 4. Load calculations per ASHRAE/ACCA Standard 183

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 2 of 2

# COMcheck Software Version 3.8.1 Mechanical Requirements Description

## 2009 IECC

### Section 1: Project Information

Project Title: Lifeline Access Center  
Construction Site: 1733 Eastchester Road, Bronx, NY 10461  
Owner/Agent: Lifeline Access Center  
Designer/Contractor: Richard J. Stem, P.E., 2741 Furnace Road, Felton, PA 17522

### Section 2: General Information

Building Location (or weather data): Bronx, New York  
Climate Zone: 4a

### Section 3: Mechanical Systems List

Quantity	System Type & Description
1	HVAC System RTU-1 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-2 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-3 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 12000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 9000 kBtu/h, Efficiency = 11.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: High Efficiency Equipment
1	HVAC System RTU-4 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 7200 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 3600 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: Filtration Requirements
1	HVAC System EDH-1 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EDH-2 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-3 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-4 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-5 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EWH-1 (Single Zone): Heating: 1 each - Unit Heater, Electric, Capacity = 6826 kBtu/h
1	Water Heater WH-1: Electric Storage Water Heater, Capacity: 100 gallons w/ Circulation Pump, Efficiency: 98.00

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 2 of 2

### Section 5: Compliance Statement

- Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed mechanical systems have been designed to meet the 2009 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

Name - Title	Signature	Date

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 4 of 7

# COMcheck Software Version 3.8.1 Mechanical Requirements Description

## 2009 IECC

### Section 1: Project Information

Project Title: Lifeline Access Center  
Construction Site: 1733 Eastchester Road, Bronx, NY 10461  
Owner/Agent: Lifeline Access Center  
Designer/Contractor: Richard J. Stem, P.E., 2741 Furnace Road, Felton, PA 17522

### Section 2: General Information

Building Location (or weather data): Bronx, New York  
Climate Zone: 4a

### Section 3: Mechanical Systems List

Quantity	System Type & Description
1	HVAC System RTU-1 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-2 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-3 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 12000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 9000 kBtu/h, Efficiency = 11.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: High Efficiency Equipment
1	HVAC System RTU-4 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 7200 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 3600 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: Filtration Requirements
1	HVAC System EDH-1 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EDH-2 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-3 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-4 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-5 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EWH-1 (Single Zone): Heating: 1 each - Unit Heater, Electric, Capacity = 6826 kBtu/h
1	Water Heater WH-1: Electric Storage Water Heater, Capacity: 100 gallons w/ Circulation Pump, Efficiency: 98.00

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 5 of 7

### Section 5: Compliance Statement

- Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed mechanical systems have been designed to meet the 2009 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

Name - Title	Signature	Date

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 6 of 7

# COMcheck Software Version 3.8.1 Mechanical Requirements Description

## 2009 IECC

### Section 1: Project Information

Project Title: Lifeline Access Center  
Construction Site: 1733 Eastchester Road, Bronx, NY 10461  
Owner/Agent: Lifeline Access Center  
Designer/Contractor: Richard J. Stem, P.E., 2741 Furnace Road, Felton, PA 17522

### Section 2: General Information

Building Location (or weather data): Bronx, New York  
Climate Zone: 4a

### Section 3: Mechanical Systems List

Quantity	System Type & Description
1	HVAC System RTU-1 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-2 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 6000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 6000 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, No Economizer, Economizer exception: Humidity Requirements
1	HVAC System RTU-3 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 12000 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 9000 kBtu/h, Efficiency = 11.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: High Efficiency Equipment
1	HVAC System RTU-4 (Single Zone): Heating: 1 each - Central Furnace, Gas, Capacity = 7200 kBtu/h, Efficiency = 80.00% EER; Cooling: 1 each - Rooftop Package Unit, Capacity = 3600 kBtu/h, Efficiency = 13.00 EER, Air-Cooled Condenser, Air Economizer, Economizer exception: Filtration Requirements
1	HVAC System EDH-1 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EDH-2 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-3 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-4 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 6826 kBtu/h
1	HVAC System EDH-5 (Single Zone): Heating: 1 each - Duct Furnace, Electric, Capacity = 3413 kBtu/h
1	HVAC System EWH-1 (Single Zone): Heating: 1 each - Unit Heater, Electric, Capacity = 6826 kBtu/h
1	Water Heater WH-1: Electric Storage Water Heater, Capacity: 100 gallons w/ Circulation Pump, Efficiency: 98.00

Project Title: Lifeline Access Center  
Data Name: C:\Users\Richard J. Stem\Documents\COMcheck\2010-11 Lifeline - Bronx NY\Calculations\COMcheck130418.LL.Bronx - COMcheck Calc.cck  
Report Date: 04/19/13  
Page 7 of 7

### Section 5: Compliance Statement

- Compliance Statement: The proposed mechanical design represented in this document is consistent with the building plans, specifications, and other calculations submitted with the permit application. The proposed mechanical systems have been designed to meet the 2009 IECC requirements in COMcheck Version 3.8.1 and to comply with the mandatory requirements in the Requirements Checklist.

Name - Title	Signature	Date

ISSUED FOR  
BUILDING PERMIT


SDI Design, LLC.  
Mechanical - Electrical  
21714 Orwig Road, #103  
Frederick, MD 21704-4374  
Fax: 410-357-4374

TENANT RENOVATIONS FOR:  
Access Center  
1733 Eastchester Road  
Bronx, NY 10461

Lifeline  
Vascular Access

INSync  
ARCHITECTURAL  
DESIGNS, INC.  
1213 Old Pikesville Road  
Whiteford, MD 21160  
Office 410-452-8006 Fax 410-452-9046

DRAWING NO.  
EN-100.00  
SHEET  
OF  
DATE: 4/19/13  
JOB NUMBER: 11206  
DRAWN BY: DUC  
CHECKED BY: SMM



### ENERGY CALCULATIONS

REV#	DATE	DESCRIPTION
1	1/8/14	CONSTRUCTION REVISIONS

