



LEGEND

EXISTING

NEW

DEMO

NOTE(S):

- 1 REBALANCE VAV (AIR AND HOT WATER FLOW) PER VAV BOX SCHEDULE.
- 2 REPLACE VAV BOX SHOWN AS NEW. SEE VAV BOX SCHEDULE FOR DETAILS.
- 3 REPLACE AHU SHOWN AS NEW. SEE AHU SCHEDULE FOR DETAILS.
- 4 REBALANCE AHU. SEE SCHEDULE FOR DETAILS.
- 5 NEW VAV BOX WILL REQUIRE NEW MP DUCT, HOT WATER PIPING, ELECTRICAL CONNECTION TO BOX AND NEW LP DUCT AND DIFFUSER FROM BOX. SEE SCHEDULE AND FLOOR PLANS FOR DETAILS.

Date	Appr.	Symbol	Description

Date	Checked by	WIT	Plot scale
02/27/04	WTT		
Date	CADD File Name	ICT Project No.	Plot date
02/27/04	312M102.DGN	203121	02/27/04
Date	Drawn by	Approved by	Chief, Proj. Mgmt. Division
02/27/04	ICT	DACAB7-03-D-0006	

TASK ORDER # FRR004

PADUCAH, KENTUCKY
VOICE 270-442-8620

ICT
L.C. Thomasson
NASHVILLE, TENNESSEE
PHONE (615) 446-3400

DEFENSE INFORMATION SCHOOL
FT. MEADE MARYLAND

AHU FLOW SCHEMATIC DIAGRAMS

Sheet reference number:
M-102

THESE DOCUMENTS HAVE BEEN PREPARED PRIMARILY BASED ON INFORMATION PROVIDED BY OTHERS. I.C. THOMASSON HAS NOT VERIFIED THE ACCURACY OF ALL INFORMATION PROVIDED BY OTHERS. SEE LIMIT OF LIABILITY STATEMENT ON COVER SHEET.

