

Date	Description	Symbol	Appr.


Date: 02/27/04	Checked by: WTT
CADD File Name: 312/M613.DGN	Des. by: ICT
ICT Project No. 203321	DAC-97-03-D-0006
Plot date: 02/27/04	Approved by:
Plot scale:	Chief, Proj. Mgmt. Division

TASK ORDER #1 FRR004	J. C. Thomasson, Inc.
PADUCAH, KENTUCKY	NASHVILLE, TENNESSEE
VOICE: 270-442-8620	PHONE: (615) 346-3400

DEFENSE INFORMATION SCHOOL
 FT. MEADE MARYLAND
 ZONE 3 - 1st FLOOR
 HW PIPING

Sheet reference number:
M-613

- NOTE(S):
- REBALANCE EXISTING HOT WATER REHEAT COIL FLOW TO INDICATED REQUIREMENTS. SEE SCHEDULE.
 - NEW HWS/R TO NEW DUCT HTG. COIL OR NEW VAV BOX. BALANCE REHEAT COIL TO INDICATED REQUIREMENTS.
 - NEW HOT WATER SUPPLY & RETURN TO NEW AHU. NEW PIPE AND ROOF PENETRATION AT EACH COIL.



THESE DOCUMENTS HAVE BEEN PREPARED PRIMARILY BASED ON INFORMATION PROVIDED BY OTHERS. J.C. THOMASSON HAS NOT VERIFIED THE ACCURACY OF ALL INFORMATION PROVIDED BY OTHERS. SEE LIMIT OF LIABILITY STATEMENT ON COVER SHEET.