

EXISTING LSD INSULATION DETAIL

NO SCALE

2nd FLOOR PLAN

0 5 10

1/16" = 1'-0"



SQUARE CEILING DIFFUSER INSULATION DETAIL

NO SCALE



NOTES:

1. INSULATE EXISTING PERIMETER SUPPLY AIR SLOT DIFFUSER (SEE LSD INSULATION DETAIL THIS SHEET.)
2. INSULATE EXISTING PERIMETER SUPPLY AIR SQUARE CEILING DIFFUSER. (SEE SQUARE CEILING DIFFUSER INSULATION DETAIL THIS SHEET.)

THESE DOCUMENTS HAVE BEEN PREPARED PRIMARILY BASED ON INFORMATION PROVIDED BY OTHERS. I.C. THOMASSON HAS NOT VERIFIED THE ACCURACY OF ALL INFORMATION PROVIDED BY OTHERS. SEE LIMIT OF LIAIBILITIES STATEMENT ON COVER SHEET.

US ARMY ENGINEERING AND SUPPORT CENTER HUNTSVILLE

Symbol	Description	Date	Appr.

Date: 02/27/04
Checked by: WTT
CADD File Name:
Drwn by: ICT
ICT Project No. 203121
DACA87-03-D-0006
Plot date: 02/27/04
Approved by:
Plot scale: 0.0104167 (1=96)
Chief, Proj. Mgmt. Division

TASK ORDER #: FRR004

ENGLAND

I.C. Thomasson Associates, Inc.
PADUCAH, KENTUCKY VOICE 270-442-8620
NASHVILLE, TENNESSEE PHONE (615) 346-3400

ICT

DEFENSE INFORMATION SCHOOL
FT. MEADE MARYLAND

2nd FLOOR SUPPLY DIFFUSER LOCATIONS

STATE OF MARYLAND — MECHANICAL ENGINEER

Sheet reference number:

M-904