

GYM OFFICE PLAN – LIGHTING ◇1

SCALE: 1/8" = 1'-0"

REFERENCED NOTES

◇1 ALL CIRCUITS ON THIS PLAN SHALL BE FED BY PANEL LPA, UNLESS NOTED OTHERWISE.

◇2 SWITCHING FOR HALF OF GYMNASIUM LIGHTING.

◇3 ONE LAMP SHALL NOT BE SWITCHED AND SHALL REMAIN ON AS NIGHT LIGHT. THE LAMP SHALL BE ON AN EMERGENCY BATTERY BACKUP.

◇4 ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 1 OR 4) SHALL FEED (4) LAMPS AND BE SWITCHED AS SHOWN. ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 2) SHALL FEED (2) LAMPS AND SWITCHED AS SHOWN. ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 3) SHALL FEED THE REMAIN (2) LAMPS AND BE SWITCHED AS SHOWN.

◇5 ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 1 OR 4) SHALL FEED (4) LAMPS AND BE SWITCHED AS SHOWN. ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 2) SHALL FEED (2) LAMPS AND BE SWITCHED AS SHOWN. ONE BALLAST AND ONE CIRCUIT (CIRCUIT NO. 3) SHALL FEED THE REMAIN (2) LAMPS AND THESE SHALL USED AS NIGHT LIGHTS AND BE CONNECTED TO THE EMERGENCY BATTERY.



MAIN FLOOR PLAN – LIGHTING ◇1

SCALE: 1/8" = 1'-0"

RUBELING & ASSOCIATES, INC.
ARCHITECTURE
INTERIOR DESIGN
401 JEFFERSON AVENUE
TOWSON, MARYLAND 21286-5308
410-337-2886
FAX 410-337-2974

Century Engineering, Inc.
32 West Road
Towson, Maryland 21204
Voice (410) 823-8070
Fax (410) 823-2164

SPORTS AND FITNESS CENTER
NOTRE DAME PREPARATORY SCHOOL

815 HAMPTON LANE
TOWSON, MARYLAND 21286

95% SUBMISSION

REVISIONS:

NO.	DESCRIPTION	DATE

LAST REV.:
PROJECT NO.: 02-037
DATE: 2-19-03
SCALE: AS NOTED

TITLE:
MAIN FLOOR PLANS –LIGHTING

SHEET:
E

102

22111.01

©RUBELING & ASSOCIATES 2002