



- NOTES:**
- THREE WAY VALVES (PNEUMATICALLY OPERATED) ARE EXISTING/RELOCATED. PROVIDE NEW CONTROL AIR SOURCE BETWEEN EXISTING PNEUMATIC ATC PANEL/TIMECLOCK ASSOCIATED WITH BUILDING ZONE HEATING CONTROL SYSTEM EXTENDED FROM EXISTING BUILDING CONTROL AIR SYSTEM.
 - EXISTING PNEUMATIC ATC PANEL/TIMECLOCK FOR CONTROL OF BUILDING ZONE HEATING SYSTEM. CONTROL OF SECONDARY DISTRIBUTION PUMPS, OUTDOOR AIR TEMPERATURE RESET BASED ON OCCUPIED/UNOCCUPIED SCHEDULE, DAY-NITE SCHEDULE AND, WARM-UP SHALL REMAIN UNCHANGED. CONTROLS CONTRACTOR SHALL REFER TO THE EXISTING BUILDING CONSTRUCTION CONTRACT DOCUMENTS DATED APRIL 21, 1959, DRAWING M-14 FOR ADDITIONAL INFORMATION AVAILABLE THROUGH THE OWNER.
 - BOILERS SHALL BE OPERATED/CONTROLLED THROUGH THE NEW CONTROL PANEL AND PACKAGED BOILER CONTROLS.
 - CONTROLS FOR EXISTING DOMESTIC HOT WATER GENERATOR HEATING HOT WATER PUMP SHALL REMAIN. PROVIDE NEW CURRENT SENSING RELAY.

BOILER REPLACEMENT FOR
NOTRE DAME PREPARATORY SCHOOL
 815 HAMPTON LANE
 TOWSON, BALTIMORE COUNTY, MARYLAND 21286



James Posey Associates
 Engineering Your Vision
 Mechanical & Electrical
 Consulting Engineers
 3112 Lord Baltimore Drive
 Baltimore, MD 21244
 tel 410-265-6100
 fax 410-298-9820
 jamesposey.com

Comm. No. 5806-09

Sym.	REVISIONS	Date

Drawn	TGS
Designed	TGS
Checked	SJH
Approved	

Scale	NONE
Comm No	5806-09
Date	4/7/2010

Drawing Title
ATC SEQUENCES

Sheet No:
M7.2