

LIGHTING FIXTURE SCHEDULE									
TYPE	MANUFACTURER	MODEL	MOUNTING	LAMPS	LUMENS	WATTAGE	EFFICACY	NOTES	
DL1	LUXRITE	L20731	RECESSED	LED	750 lm	10.5 W	71 lm/W	4" CANLESS DOWNLIGHT, 3500K, ENERGY STAR CERTIFIED	
DL2	LUXRITE	L20731	RECESSED	LED	800 lm	10.0 W	80 lm/W	4" CANLESS DOWNLIGHT, FIRE RATED, 3500K, ENERGY STAR CERTIFIED	
EX1	ACUTY	ARUE3	POLE	LED		0.0 W	0 lm/W	SITE LIGHT, 3000K, BLACK FINISH, 70W, DELMARVA POWER PROVIDED AND INSTALLED.	
EX2	MORRIS	71423C	SURFACE	LED	2068 lm	9.3 W	159 lm/W	LED WALL PACK, 3000K, DARK SKY COMPLIANT	
FL	BROAD	4E8BSL	SURFACE	LED	0 lm	11.0 W	0 lm/W	EXHAUST FANLIGHT, 3500K, ENERGY STAR CERTIFIED	
PF	NATHAN JAMES	12302	PENDANT	(2) LED A19 BULBS	1620 lm	18.0 W	90 lm/W	TWIN PENDANT FIXTURE, 3000K, ENERGY STAR CERTIFIED	
SM	LUMENS ALDER & ORE	DARIA LED	SURFACE	LED	1600 lm	20.0 W	80 lm/W	SURFACE MOUNT CYLINDER, 3500K, ENERGY STAR CERTIFIED	
VL	PROGRESS	P2158-31	SURFACE	(2) LED A19 BULBS	1620 lm	18.0 W	90 lm/W	Vanity Light, 3000K, ENERGY STAR CERTIFIED	
WS2	PEARED CREATION	2860	SURFACE	(2) LED A19 BULBS	1620 lm	18.0 W	90 lm/W	WALL SCONCE - INTERIOR, 3000K, ENERGY STAR CERTIFIED	
X1	Dual Use	LES-VARIES-VARIES-S-G-X-N	SURFACE	LED				Coordinate number of faces and arrows with plans	

SPACE CONTROLS OPERATIONAL MATRIX													
LOCATION		SWITCHING/ DIMMING			MISCELLANEOUS								
NUMBER	NAME	SWITCHING	STEP-DIMMING OR DUAL SWITCHING	FULL RANGE DIMMING	OCCUPANCY SENSOR TIME/OUT DELAY (IN MINUTES)	OCCUPANCY SENSOR MANUAL ON (VACANCY?)	OCCUPANCY SENSOR AUTOMATIC ON 100% LIGHT LEVEL	OCC. SENSOR 50% LIGHT LEVEL AUTO ON 100% MANUAL ON	TIMECLOCK SCHEDULED ON TIME	TIMECLOCK SCHEDULED ON TIME	OCC. SENSOR OVERMODE TIMECLOCK DURING "OFF" HOURS	DAYLIGHTING-DIM LIGHTS TO MAINTAIN MINIMUM 50FC AT 30' AFF	COMMENTS
1BR	B												
	SWITCH - SINGLE POLE												
2BR	D												
	SWITCH - SINGLE POLE												
LC12	Space												
LC13	Space												
LC14	LOUNGE AREA												
	OCCUPANCY SENSOR - ceiling												
LC15	OFFICE			X	15		X	X					
	Low Voltage Switch - Dimmer												
	OCCUPANCY SENSOR - ceiling												
LC16	TOILET	X			15				7AM	8PM	X		
	OCCUPANCY SENSOR - WALL												
	SWITCH - SINGLE POLE												
LC17	CORRIDOR	X		X	15				7AM	8PM		X	OVER-RIDE SWITCHES ARE REQUIRED
	Low Voltage Switch - Dimmer												
	OCCUPANCY SENSOR - ceiling												